

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 112/2021-22

Date: 08/06/2021

It is certified that an inspection team headed by Dr N.C. Tiwari
med. Suppl. (Name of Officers with designation) from
Community Health Center Bhimtal (Name
of Department/Office) inspected the G. D. Goenka International
School Naulkuchital Bhimtal (Name & Address
of the School) on 08/06/2021 and found that the
G.D. Goenka International School (Name of school) has
safe drinking water facilities for the students and members of staff of the institution and is
maintaining the hygienic sanitation condition in the school building & the campus as per the
norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 yr (one yrs)

Signature with Seal: [Signature]

Name: Dr N.C. Tiwari

Designation: med Suppl.

Medical Superintendent
C.H.C. Bhimtal
(Nainital)

To

Principal G.D
Goenka International
School Naulkuchital Bhimtal
(Name & Address of the Institution) Dist. Nainital,





District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Nainital
Ph (O): 05942-235428, E-mail: ceujstnl@gmail.com



TC-10007

Test Report ID: 64 /UJS/DLWQTML/2022-23

URL No - TC100072200000058F
Dated:-13/05/2022

WATER QUALITY TEST REPORT

Name and Address of Organization/ Customer	G.D Goenka International School, Naukuchital, Nainital		
Type of Source (Surface Water/ Ground Water/ Sub-Surface Water)	Ground Water	Sample Description	Drinking Water / Entire Complex RO Water
Reference Sample Identification:	DLWQTML/UJS/GDGIS		Date of Start of Analysis:- 11/05/2022
			Date of End of Analysis :- 13/05/2022
Date and Time of Sample Received:- 11/05/2022 & 4:20pm	Sample Collected by:		Customer

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS)	Std. Test Method
1	pH, at 25 °C	7.47	6.5 to 8.5	No Relaxation	IS 3025 (Part 11)-2002
2	Total Dissolved Solids (TDS), mg/l.	142.0	500	2000	IS 3025 (Part 11)-2002
3	Turbidity, NTU	0.28	1	5	IS 3025 (Part 16)-2006
4	Total Alkalinity (as CaCO ₃), mg/L	72.0	200	600	IS 3025 (Part 10)-2006
5	Total Hardness (as CaCO ₃), mg/L	86.0	200	600	IS 3025 (Part 23)-2003
6	Calcium (as Ca), mg/L	20.8	75	200	IS 3025 (Part 40) : 1983
7	Colour, Hazen	4.0	5	15	IS 3025 (Part 4) : 1983
8	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8) : 1984
9	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5) : 1983
10	Chloride, mg/l	12.0	250	1000	IS 3025 (Part 32) : 1988
11	Magnesium (as Mg), mg/L	8.2	30	100	APHA 23rd 3500Mg Method B :2017
12	Residual Free Chlorine, mg/L	Absent	0.2	1.0	IS 3025 (Part 16) : 1984
13	Total Coliform (MPN/100ml)	Absent	Absent	Absent	APHA 23 rd Ed.-9223.B
14	E.Coli (MPN/100ml)	Absent	Absent	Absent	APHA 23 rd Ed.-9223.B

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.



-End of Report-

- The results listed refer only to tested sample and applicable parameters.
- This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
- The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.